

**Bill Bradbury**  
Chair  
Oregon

**Henry Lorenzen**  
Oregon

**W. Bill Booth**  
Idaho

**James A. Yost**  
Idaho



## Northwest Power and Conservation Council

**Jennifer Anders**  
Vice Chair  
Montana

**Pat Smith**  
Montana

**Tom Karier**  
Washington

**Phil Rockefeller**  
Washington

April 29, 2014

### MEMORANDUM

**TO:** Council Members

**FROM:** John Fazio, Senior Power Systems Analyst

**SUBJECT:** Council Decision to Release the 2019 Resource Adequacy Assessment

At the Council meeting on May 7, 2014, staff will brief the Council on the assessment of regional power supply adequacy for the operating year 2019. The Power Committee will have already discussed the assessment on May 6 and if they so recommend, the Council will vote on approving the adequacy assessment and on releasing the report.

The power supply for the Pacific Northwest is deemed adequate if the likelihood of future shortages, measured as loss of load probability or LOLP, is less than five percent. The Council approved the last adequacy assessment in December 2012. That assessment reported an LOLP of about 7 percent for 2017.

The current resource adequacy assessment shows a 6 percent LOLP for 2019. In 2021, after the Boardman and Centralia 1 coal plants (total 1,300 megawatts) are retired, the LOLP rises to 11 percent.

The LOLP results dropped from 7 percent for 2017 to 6 percent for 2019 primarily because anticipated resource additions are expected to be greater than forecast load growth. These results assume that the Council's annual energy efficiency savings target of about 350 average megawatts is achieved between 2017 and 2019.

Actions to bring the 2019 and 2021 power supplies into compliance with the Council's 5 percent LOLP standard will vary depending on the types of new generating resources or demand reduction programs that are considered. It is beyond the scope of this analysis to develop a resource acquisition strategy. That is done in the Council's power plan. However, PNUCC's 2014 Northwest Regional Forecast shows the sum of utility planned resources through 2024 to be about 1,800 megawatts.

# Resource Adequacy

## Final Assessment for 2019

Council Meeting  
Boise, Idaho  
May 7, 2014

# Outline


- 1. Council's Adequacy Standard**
- 2. Adequacy Assessment History**
- 3. Import Recommendation**
- 4. 2019 and 2021 Assessments**
- 5. EE Savings Impacts**
- 6. Discussion of Final Report**

# Council's Adequacy Standard (Adopted in 2011)

- **Metric = Loss of Load Probability**
- **Threshold = 5% (Max allowable LOLP)**
  
- **Other adequacy metrics:**
  - **Number of curtailments per year**
  - **Average size of curtailment**
  - **Average duration (hours) of curtailment**

# Loss of Load Probability

Each bin = 1 simulation



Each red bin = Simulation with at least 1 curtailment

Out of 10,000 simulations, 500 had at least one curtailment event  
Loss of Load Probability (LOLP) =  $500/10,000 = 5$  percent

# Adequacy Assessment History

- **1998** – Large load/resource balance deficit concern
- **1999** – Ad-hoc committee recommended using LOLP
- **2000** – **First assessment yields a 24% LOLP**
- **2001** – West Coast energy crisis
- **2005** – Resource Adequacy Forum is created
- **2007** – Unofficial assessment: adequate power supply
- **2008** – Council adopts first NW adequacy standard
- **2009-10** – Adequacy methodology peer reviewed
- **2010** – **Council's 6<sup>th</sup> power plan shows a 5% LOLP for 2015**
- **2011** – Council revises the adequacy standard
- **2012** – **2017 assessment: LOLP 7%**

# GENESYS Northwest

Monte Carlo Simulation of the NW Power Supply


Project-level Monthly Hydro Simulation

Hourly Economic Dispatch (including hydro)

Inter-regional Transmission Capacity (but not forced outages)

## Random Variables:


- Water Conditions
- Temperature/Loads
- Resource Forced Outage
- Wind



# Transmission Modeled in GENESYS

NW region includes:  
East (E)  
West (W)  
Captain Jack (CJ)

Solid lines indicate transmission into and out of the region





# Import Recommendation **2,500 MW**

## Import Availability and Tie Limits<sup>1</sup> (MW)

<b>Month</b>	<b>SW Supply</b>	<b>5% Lowest Intertie</b>	<b>Assumed Limit</b>
<b>Jan</b>	16,529	3,425	2,500
<b>Feb</b>	15,937	3,425	2,500
<b>Mar</b>	17,316	2,450	2,500
<b>Oct</b>	21,923	2,450	2,500
<b>Nov</b>	20,264	3,425	2,500
<b>Dec</b>	17,929	3,425	2,500

<sup>1</sup>Celilo-Sylmar DC transmission line is scheduled to be upgraded by up to 700 MW by 2019.

# Changes Since 2017 Assessment

**2017 LOLP:**

**7%**

- Net Load Growth 206 MWa  
(including 700 MWa Energy Efficiency Savings)
- Southwest Imports 800 MW
- New Gas-Fired Generation 670 MW
- New Wind 260 MW
- Standby Energy - 42,200 MW-hours
- Standby Winter Capacity - 37 MW
- Standby Summer Capacity 113 MW

**2019 LOLP:**

**6%**

# LOLP Sensitivities 2019 (%)

7.5

Low Load  
0 Import

10.5

Med Load  
0 Import

14.9

High Load  
0 Import

4.0

Low Load  
2500 Import

5.9

Med Load  
2500 Import

8.5

High Load  
2500 Import

3.7

Low Load  
3400 Import

5.3

Med Load  
3400 Import

7.7


High Load  
3400 Import

# LOLP Results for 2019 (%)


(Effects of Load and Import Uncertainties)

Load	-2.5%	-1.5%	Medium	+1.5%	+2.5%
<b>Import</b>					
0 (MW)	7.5	8.6	10.5	12.9	14.9
1700	4.5	5.3	6.5	8.0	9.3
2000	4.3	4.9	6.2	7.7	9.0
2500	4.0	4.7	5.9	7.2	8.5
3000	3.8	4.5	5.4	6.7	7.9
3400	3.7	4.4	5.3	6.4	7.7

# Precision of LOLP $\pm$ 5% of Value



# Effect of EE on LOLP (approx.)



# 2021 Assessment

**2019 LOLP:**

**6%**

- Net Load Growth                      206 MWa  
( including 700 MWa Energy Efficiency Savings)
- Coal Retirements                      - 1,300 MW

**2021 LOLP:**

**11%**

# Summary of Adequacy Report

1. **2019 LOLP = 6%**
2. **2019 LOLP = 5%** +400 MW capacity, or +300 MWa EE savings<sup>1</sup>
3. **2019 LOLP > 7%** with half of EE savings
4. **2021 LOLP = 11%** -1,300 MW coal capacity
5. PGE Boardman replacement strategy by 2019
6. Sum of utility planned new generating resources 1,800 MW by 2024
7. Assume EE shape = load shape, need better data
8. Lots of SW winter surplus power supply available: address new intertie transmission to help meet needs

<sup>1</sup>Estimated by reducing loads 300 MWa, since the EE hourly shape is the same as the load shape in our analysis.